



4505 131st Ave N, Suite 27, Clearwater, FL 33762 Tel: (727) 561-7697 (800) 622-9904 Fax: (727) 556-0182

September 14, 2010

Attn: Vendors currently stocking the SCM150 and SCM60 units

Notice of Mandatory Product Recall

To Whom It May Concern:

The SCM150 and SCM60 units that you have in stock as well as units purchased this calendar year are labeled incorrectly per UL guidelines, please get in contact with Justin Turner at (727) 561-7697 ext. 20 to set up the return of these units to the factory for relabeling. This is for the SCM150 and SCM60 products that you currently have in stock, they are not currently able to be sold as they have the wrong label on them and don't comply with the UL guidelines. We apologize for any inconvenience and will do whatever necessary to get these units corrected and back out to you in the least amount of time possible. Thank you for your time.

Best Regards,

Justin Turner
Operations Manager
Sycom Surge, Inc.